

# Water Chemistry Sheet

Everything Swimming Pools [www.everythingswimmingpools.com](http://www.everythingswimmingpools.com)  
 858-693-3307 [info@everythingswimmingpools.com](mailto:info@everythingswimmingpools.com)

Everything Swimming Pools recommend the use of a stain preventative, (one half quart per month per 20,000 gallons or less) to help reduce the effects of mineral and metal staining to the swimming pool and spa surfaces.

If any of these ranges are out of balance please call for information or assistance in resolving water chemistry issues.

And if you are above the recommended total dissolved solids, the swimming pool or spa should have a partial/complete drain and restart to help ensure proper water balance.

When testing Total Dissolved Solids, always subtract the salt level from the TDS to know what the true TDS is.

Monitor	Chemisty	Minimum	Maximum	Test	Difference
Initially	Calcium Hardness	200 PPM	400 PPM		
Biweekly	Total Alkalinity	90 PPM	120 PPM		
Weekly	pH	pH 7.4	pH 7.6		
Weekly	Free Chlorine	1 PPM	3 PPM		
Biweekly	Phosphates	zero 0	125 PPB		
Monthly	CYA (Stabilizer)	20 PPM	40 PPM		
Quarterly	Total Dissolved Solids		2500 PPM		
Monthly	Salt levels	Per Manufacturer Recommendations			

